

This information was generated by the HP KEYMARK database on 9 Sep 2021

[Login](#)

Summary of	R32 Hydrosplit 12 14 16 kW 1 phase & 3 phases	Reg. No.	011-1W0382
Certificate Holder			
Name	LG Electronics Inc.		
Address	84, Wanam-ro, seongsan-gu	Zip	51554
City	Changwon-si	Country	South Korea
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	R32 Hydrosplit 12 14 16 kW 1 phase & 3 phases		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	2.1 kg		
Certification Date	06.07.2020		
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 8 (as of 2020-09)		

Model: HU121MRB U30 / HN1600MB NK0

Configure model	
Model name	HU121MRB U30 / HN1600MB NK0
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.00 kW	11.00 kW
El input	2.38 kW	3.79 kW
COP	5.04	2.90

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	181 %	137 %
Prated	12.00 kW	12.00 kW
SCOP	4.60	3.50
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.20 kW	10.20 kW
COP Tj = -7°C	3.01	2.20
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.20 kW	6.30 kW
COP Tj = +2°C	4.42	3.38
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	6.04	4.67
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 9 Sep 2021

Pdh Tj = 12°C	5.00 kW	4.60 kW
COP Tj = 12°C	8.44	6.66
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	11.50 kW	10.20 kW
COP Tj = Tbiv	2.65	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.50 kW	10.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.92
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	1.20 kW
Annual energy consumption Qhe	5165 kWh	6788 kWh

Model: HU123MRB U30 / HN1600MB NK0

Configure model	
Model name	HU123MRB U30 / HN1600MB NK0
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.00 kW	11.00 kW
El input	2.38 kW	3.79 kW
COP	5.04	2.90

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 9 Sep 2021

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	181 %	137 %
Prated	12.00 kW	12.00 kW
SCOP	4.60	3.50
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.20 kW	10.20 kW
COP Tj = -7°C	3.01	2.20
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.20 kW	6.30 kW
COP Tj = +2°C	4.42	3.38
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	6.04	4.67
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 9 Sep 2021

Pdh Tj = 12°C	5.00 kW	4.60 kW
COP Tj = 12°C	8.44	6.66
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	11.50 kW	10.20 kW
COP Tj = Tbiv	2.65	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.50 kW	10.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.92
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	1.20 kW
Annual energy consumption Qhe	5165 kWh	6788 kWh

Model: HU141MRB U30 / HN1600MB NK0

Configure model	
Model name	HU141MRB U30 / HN1600MB NK0
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	11.50 kW
El input	2.86 kW	4.04 kW
COP	4.89	2.85

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	180 %	136 %
Prated	12.00 kW	12.00 kW
SCOP	4.57	3.47
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.60 kW	10.40 kW
COP Tj = -7°C	2.94	2.16
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.50 kW	6.30 kW
COP Tj = +2°C	4.45	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.70 kW	4.70 kW
COP Tj = +7°C	5.95	4.66
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 9 Sep 2021

Pdh Tj = 12°C	5.00 kW	4.60 kW
COP Tj = 12°C	8.12	6.62
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.00 kW	10.40 kW
COP Tj = Tbiv	2.60	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	10.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.86
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	1.10 kW
Annual energy consumption Qhe	5425 kWh	6992 kWh

Model: HU143MRB U30 / HN1600MB NK0

Configure model	
Model name	HU143MRB U30 / HN1600MB NK0
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	11.50 kW
El input	2.86 kW	4.04 kW
COP	4.89	2.85

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	180 %	136 %
Prated	12.00 kW	12.00 kW
SCOP	4.57	3.47
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.60 kW	10.40 kW
COP Tj = -7°C	2.94	2.16
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.50 kW	6.30 kW
COP Tj = +2°C	4.45	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.70 kW	4.70 kW
COP Tj = +7°C	5.95	4.66
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 9 Sep 2021

Pdh Tj = 12°C	5.00 kW	4.60 kW
COP Tj = 12°C	8.12	6.62
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.00 kW	10.40 kW
COP Tj = Tbiv	2.60	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	10.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.86
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	1.10 kW
Annual energy consumption Qhe	5425 kWh	6992 kWh

Model: HU161MRB U30 / HN1600MB NK0

Configure model	
Model name	HU161MRB U30 / HN1600MB NK0
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	12.00 kW
El input	3.33 kW	4.29 kW
COP	4.80	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	179 %	135 %
Prated	12.00 kW	12.00 kW
SCOP	4.55	3.45
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.90 kW	10.60 kW
COP Tj = -7°C	2.88	2.15
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.70 kW	6.50 kW
COP Tj = +2°C	4.45	3.34
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.00 kW	5.20 kW
COP Tj = +7°C	5.97	4.65
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 9 Sep 2021

Pdh Tj = 12°C	5.30 kW	4.60 kW
COP Tj = 12°C	8.11	6.58
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.30 kW	10.60 kW
COP Tj = Tbiv	2.56	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.30 kW	11.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.85
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	5586 kWh	7187 kWh

Model: HU163MRB U30 / HN1600MB NK0

Configure model	
Model name	HU163MRB U30 / HN1600MB NK0
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	12.00 kW
El input	3.33 kW	4.29 kW
COP	4.80	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	179 %	135 %
Prated	12.00 kW	12.00 kW
SCOP	4.55	3.45
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.90 kW	10.60 kW
COP Tj = -7°C	2.88	2.15
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.70 kW	6.50 kW
COP Tj = +2°C	4.45	3.34
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.00 kW	5.20 kW
COP Tj = +7°C	5.97	4.65
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 9 Sep 2021

Pdh Tj = 12°C	5.30 kW	4.60 kW
COP Tj = 12°C	8.11	6.58
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.30 kW	10.60 kW
COP Tj = Tbiv	2.56	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.30 kW	11.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.85
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	5586 kWh	7187 kWh

Model: HU121MRB U30 / HN1600MC NK1

Configure model	
Model name	HU121MRB U30 / HN1600MC NK1
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.00 kW	11.00 kW
El input	2.38 kW	3.79 kW
COP	5.04	2.90

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	181 %	137 %
Prated	12.00 kW	12.00 kW
SCOP	4.60	3.50
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.20 kW	10.20 kW
COP Tj = -7°C	3.01	2.20
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.20 kW	6.30 kW
COP Tj = +2°C	4.42	3.38
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	6.04	4.67
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 9 Sep 2021

Pdh Tj = 12°C	5.00 kW	4.60 kW
COP Tj = 12°C	8.44	6.66
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	11.50 kW	10.20 kW
COP Tj = Tbiv	2.65	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.50 kW	10.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.92
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	1.20 kW
Annual energy consumption Qhe	5165 kWh	6788 kWh

Model: HU123MRB U30 / HN1600MC NK1

Configure model	
Model name	HU123MRB U30 / HN1600MC NK1
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.00 kW	11.00 kW
El input	2.38 kW	3.79 kW
COP	5.04	2.90

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	181 %	137 %
Prated	12.00 kW	12.00 kW
SCOP	4.60	3.50
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.20 kW	10.20 kW
COP Tj = -7°C	3.01	2.20
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.20 kW	6.30 kW
COP Tj = +2°C	4.42	3.38
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	6.04	4.67
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 9 Sep 2021

Pdh Tj = 12°C	5.00 kW	4.60 kW
COP Tj = 12°C	8.44	6.66
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	11.50 kW	10.20 kW
COP Tj = Tbiv	2.65	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.50 kW	10.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.92
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	1.20 kW
Annual energy consumption Qhe	5165 kWh	6788 kWh

Model: HU141MRB U30 / HN1600MC NK1

Configure model	
Model name	HU141MRB U30 / HN1600MC NK1
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	11.50 kW
El input	2.86 kW	4.04 kW
COP	4.89	2.85

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	180 %	136 %
Prated	12.00 kW	12.00 kW
SCOP	4.57	3.47
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.60 kW	10.40 kW
COP Tj = -7°C	2.94	2.16
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.50 kW	6.30 kW
COP Tj = +2°C	4.45	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.70 kW	4.70 kW
COP Tj = +7°C	5.95	4.66
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 9 Sep 2021

Pdh Tj = 12°C	5.00 kW	4.60 kW
COP Tj = 12°C	8.12	6.62
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.00 kW	10.40 kW
COP Tj = Tbiv	2.60	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	10.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.86
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	1.10 kW
Annual energy consumption Qhe	5425 kWh	6992 kWh

Model: HU143MRB U30 / HN1600MC NK1

Configure model	
Model name	HU143MRB U30 / HN1600MC NK1
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	11.50 kW
El input	2.86 kW	4.04 kW
COP	4.89	2.85

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	180 %	136 %
Prated	12.00 kW	12.00 kW
SCOP	4.57	3.47
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.60 kW	10.40 kW
COP Tj = -7°C	2.94	2.16
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.50 kW	6.30 kW
COP Tj = +2°C	4.45	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.70 kW	4.70 kW
COP Tj = +7°C	5.95	4.66
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 9 Sep 2021

Pdh Tj = 12°C	5.00 kW	4.60 kW
COP Tj = 12°C	8.12	6.62
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.00 kW	10.40 kW
COP Tj = Tbiv	2.60	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	10.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.86
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	1.10 kW
Annual energy consumption Qhe	5425 kWh	6992 kWh

Model: HU161MRB U30 / HN1600MC NK1

Configure model	
Model name	HU161MRB U30 / HN1600MC NK1
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	12.00 kW
El input	3.33 kW	4.29 kW
COP	4.80	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	179 %	135 %
Prated	12.00 kW	12.00 kW
SCOP	4.55	3.45
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.90 kW	10.60 kW
COP Tj = -7°C	2.88	2.15
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.70 kW	6.50 kW
COP Tj = +2°C	4.45	3.34
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.00 kW	5.20 kW
COP Tj = +7°C	5.97	4.65
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 9 Sep 2021

Pdh Tj = 12°C	5.30 kW	4.60 kW
COP Tj = 12°C	8.11	6.58
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.30 kW	10.60 kW
COP Tj = Tbiv	2.56	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.30 kW	11.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.85
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	5586 kWh	7187 kWh

Model: HU163MRB U30 / HN1600MC NK1

Configure model	
Model name	HU163MRB U30 / HN1600MC NK1
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	12.00 kW
El input	3.33 kW	4.29 kW
COP	4.80	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	179 %	135 %
Prated	12.00 kW	12.00 kW
SCOP	4.55	3.45
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.90 kW	10.60 kW
COP Tj = -7°C	2.88	2.15
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.70 kW	6.50 kW
COP Tj = +2°C	4.45	3.34
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.00 kW	5.20 kW
COP Tj = +7°C	5.97	4.65
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 9 Sep 2021

Pdh Tj = 12°C	5.30 kW	4.60 kW
COP Tj = 12°C	8.11	6.58
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.30 kW	10.60 kW
COP Tj = Tbiv	2.56	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.30 kW	11.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.85
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	5586 kWh	7187 kWh