

Page 1 of 10

This information was downloaded from the HP KEYMARK database on 29 Oct 2020

Summary of	THERMA V_R32 Split 5 7 9 kW	Reg. No.	011-1W0315
Certificate Holder			
Name	LG Electronics Inc.		
Address	84, Wanam-ro, seongsan-gu Zip 51554		51554
City	Changwon-si	Country	South Korea
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	TÜV Rheinland Energy GmbH		
Subtype title	THERMA V_R32 Split 5 7 9 kW		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	HFC-32		
Mass Of Refrigerant	1.5 kg		
Certification Date	05.03.2019		
Testing basis	n/a		



# Model: HU091MR U44, HN0916M NK4

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	9.00 kW	5.50 kW	
El input	1.94 kW	2.04 kW	
СОР	4.65	2.70	
Indoor water flow rate	1.55 m³/h	0.59 m³/h	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

#### Average Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 3 of 10

This information was downloaded from the HP KEYMARK database on 29 Oct 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
η <sub>s</sub>	183 %	126 %
Prated	6.00 kW	6.00 kW
SCOP	4.65	3.23
Tbiv	-10 °C	-7 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	5.31 kW	5.31 kW
COP Tj = -7°C	2.75	2.05
Cdh	0.90	0.90
Pdh Tj = +2°C	3.23 kW	3.23 kW
COP Tj = +2°C	4.50	3.10
Cdh	0.90	0.90
Pdh Tj = +7°C	2.38 kW	3.00 kW
COP Tj = +7°C	6.50	4.50
Cdh	0.90	0.90

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 10

|--|

Pdh Tj = 12°C	2.80 kW	3.60 kW
COP Tj = 12°C	9.00	6.80
Cdh	0.90	0.90
Pdh Tj = Tbiv	6.00 kW	5.31 kW
COP Tj = Tbiv	2.45	2.05
Pdh Tj = TOL	6.00 kW	5.10 kW
COP Tj = TOL	2.45	1.65
WTOL	65 °C	65 °C
Poff	20 W	20 W
РТО	20 W	20 W
PSB	20 W	20 W
РСК	30 W	30 W
Supplementary Heater: Type of energy input	N/A	electric
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	2669 kWh	3843 kWh



# Model: HU071MR U44, HN0916M NK4

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.00 kW	5.50 kW
El input	1.43 kW	2.04 kW
СОР	4.90	2.70
Indoor water flow rate	1.21 m³/h	0.59 m³/h

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

#### Average Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 6 of 10

This information was downloaded from the HP KEYMARK database on 29 Oct 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825				
	Low temperature	Medium temperature		
η <sub>s</sub>	183 %	126 %		
Prated	6.00 kW	6.00 kW		
SCOP	4.65	3.23		
Tbiv	-10 °C	-7 °C		
TOL	-15 °C	-15 °C		
Pdh Tj = -7°C	5.10 kW	5.30 kW		
COP Tj = -7°C	2.80	2.05		
Cdh	0.90	0.90		
Pdh Tj = +2°C	3.10 kW	3.20 kW		
COP Tj = +2°C	4.50	3.10		
Cdh	0.90	0.90		
Pdh Tj = +7°C	2.40 kW	3.00 kW		
COP Tj = +7°C	6.50	4.50		
Cdh	0.90	0.90		

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 7 of 10

This information was	downloaded from the	HP KEYMARK databas	se on 29 Oct 2020
----------------------	---------------------	--------------------	-------------------

Pdh Tj = 12°C	2.70 kW	3.60 kW
COP Tj = 12°C	9.00	6.80
Cdh	0.90	0.90
Pdh Tj = Tbiv	5.80 kW	5.30 kW
COP Tj = Tbiv	2.50	2.05
Pdh Tj = TOL	5.80 kW	5.10 kW
COP Tj = TOL	2.50	1.65
WTOL	65 °C	65 °C
Poff	20 W	20 W
РТО	20 W	20 W
PSB	20 W	20 W
РСК	30 W	30 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.20 kW	0.90 kW
Annual energy consumption Qhe	2552 kWh	3843 kWh



# Model: HU051MR U44, HN0916M NK4

General Data		
Power supply	1x230V 50Hz	

## Heating

EN 14511-2				
	Low temperature	Medium temperature		
Heat output	5.50 kW	5.50 kW		
El input	1.12 kW	2.04 kW		
СОР	4.90	2.70		
Indoor water flow rate	0.95 m³/h	0.59 m³/h		

EN 14511-4			
Shutting off the heat transfer medium flow	passed		
Complete power supply failure	passed		
Defrost test	passed		
Starting and operating test	passed		

#### Average Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 9 of 10

This information was downloaded from the HP KEYMARK database on 29 Oct 2020

EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	44 dB(A)	44 dB(A)		
Sound power level outdoor	60 dB(A)	60 dB(A)		

EN 14825				
	Low temperature	Medium temperature		
η <sub>s</sub>	183 %	126 %		
Prated	6.00 kW	6.00 kW		
SCOP	4.65	3.23		
Tbiv	-10 °C	-7 °C		
TOL	-15 °C	-15 °C		
Pdh Tj = -7°C	4.87 kW	5.31 kW		
COP Tj = -7°C	2.80	2.05		
Cdh	0.90	0.90		
Pdh Tj = +2°C	2.96 kW	3.23 kW		
COP Tj = +2°C	4.50	3.10		
Cdh	0.90	0.90		
Pdh Tj = +7°C	2.20 kW	3.00 kW		
$COP Tj = +7^{\circ}C$	6.40	4.50		
Cdh	0.90	0.90		

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 10 of 10

Thi	s information v	was downloa	ded from the	HP KEYMARK	database on	1 29 O	ct 2020
-----	-----------------	-------------	--------------	------------	-------------	--------	---------

Pdh Tj = 12°C	2.60 kW	3.60 kW
COP Tj = 12°C	9.20	6.80
Cdh	0.90	0.90
Pdh Tj = Tbiv	5.50 kW	5.31 kW
COP Tj = Tbiv	2.50	2.05
Pdh Tj = TOL	5.50 kW	5.10 kW
COP Tj = TOL	2.50	1.65
WTOL	65 °C	65 °C
Poff	20 W	20 W
РТО	20 W	20 W
PSB	20 W	20 W
РСК	30 W	30 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.50 kW	0.90 kW
Annual energy consumption Qhe	2444 kWh	3843 kWh