

MITSUBISHI ELECTRIC
AIR CONDITIONING SYSTEMS EUROPE LTD.
 NETTLEHILL ROAD
 HOUSTOUN INDUSTRIAL ESTATE
 LIVINGSTON, EH54 5EQ, U.K.
 Telephone: +44 (0)1506 445500
 Fax: +44 (0)1506 445511

DECLARATION OF CONFORMITY

This declaration of conformity is issued under the sole responsibility of the manufacturer.

We MITSUBISHI ELECTRIC AIR CONDITIONING SYSTEMS EUROPE LTD.

NETTLEHILL ROAD HOUSTOUN INDUSTRIAL ESTATE LIVINGSTON EH54 5EQ SCOTLAND,
 UNITED KINGDOM

are the manufacturer of below models and hereby declares under its sole responsibility that the Air to Water System, Hydro Box described below for use in residential, commercial and light-industrial environments:

MITSUBISHI ELECTRIC, EHSD-MED, EHSD-VM2D, EHSD-VM6D, EHSD-YM9D, EHSD-YM9ED, EHSD-TM9D, ERSD-MED, ERSD-VM2D, EHSC-MED, EHSC-VM2D, EHSC-VM6D, EHSC-YM9D, EHSC-YM9ED, EHSC-TM9D, ERSC-MED, ERSC-VM2D, EHSE-MED, EHSE-YM9ED, ERSE-MED, ERSE-YM9ED, EHPX-MED, EHPX-VM2D, EHPX-VM6D, EHPX-YM9D, EHPX-YM9ED


comply with the provisions of the following European Directives, the harmonised standards and the specifications.:

Directives	Standards / Specifications
2014/35/EU: Low Voltage Directive	EN 60335-1:2002 / A11:2004 / A1:2004 / A12:2006 / A2:2006 / A13:2008 / A14:2010 / A15:2011, EN 60335-2-40:2003 / A11:2004 / A12:2005 / A1:2006 / A2:2009 / A13:2012, EN 62233: 2008, IEC 60335-1:2010 / A1:2013 / A2:2016, IEC 60335-2-40:2018
2006/42/EC: Machinery Directive	EN 60335-1:2002 / A11:2004 / A1:2004 / A12:2006 / A2:2006 / A13:2008 / A14:2010 / A15:2011, EN 60335-2-40:2003 / A11:2004 / A12:2005 / A1:2006 / A2:2009 / A13:2012
2014/30/EU: Electromagnetic Compatibility Directive	EN 55014-1: 2006 / A1:2009 / A2:2011, EN 61000-3-2: 2014, EN 61000-3-3: 2013, EN 55014-2: 1997 / A1: 2001 / A2: 2008 (Category IV)
2011/65/EU, (EU) 2015/863 and (EU) 2017/2102: RoHS Directive	EN 50581:2012
2009/125/EC: Energy-related Products Directive and Regulation (EU) No 813/2013	EN 12102-1:2017, EN 14511-2:2013, EN 14511-3:2013, EN 14825:2016, EN 16147:2011

Please refer to <http://erp.mitsubishielectric.eu/erp> for more information of 2009/125/EC.

Issued date: 1 September, 2019

Revised date: ---



Atsushi EDAYOSHI

Manager, Quality Assurance Department

UNITED KINGDOM

CE2019C46

DECLARATION OF CONFORMITY

This declaration of conformity is issued under the sole responsibility of the manufacturer.

We MITSUBISHI ELECTRIC CORPORATION

TOKYO BUILDING, 2-7-3, MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN

are the manufacturer of below model and hereby declares under its sole responsibility that the Air to Water Heat Pump described below for use in residential, commercial and light-industrial environments:

MITSUBISHI ELECTRIC, PUHZ-SHW230YKA2

comply with the provisions of the following European Directives, the harmonised standards and the specifications.:

Directives	Standards / Specifications
2014/35/EU: Low Voltage Directive	EN 60335-1:2002 / A11:2004 / A1:2004 / A12:2006 / A2:2006 / A13:2008 / A14:2010 / A15:2011, EN 60335-2-40:2003 / A11:2004 / A12:2005 / A1:2006 / A2:2009 / A13:2012, EN 62233: 2008
2006/42/EC: Machinery Directive	EN 60335-1:2002 / A11:2004 / A1:2004 / A12:2006 / A2:2006 / A13:2008 / A14:2010 / A15:2011, EN 60335-2-40:2003 / A11:2004 / A12:2005 / A1:2006 / A2:2009 / A13:2012
2014/30/EU: Electromagnetic Compatibility Directive	EN 55014-1: 2006 / A1:2009 / A2:2011, EN 61000-3-12: 2008, EN 61000-3-11: 2000, EN 55014-2: 1997 / A1: 2001 / A2: 2008 (Category IV)
2011/65/EU, (EU) 2015/863 and (EU) 2017/2102: RoHS Directive	EN 50581:2012
2009/125/EC: Energy-related Products Directive, Regulation (EU) No 813/2013 and Regulation (EU) No 2016/2281	EN 12102:2013, EN 14511-2:2013, EN 14511-3:2013, EN 14825:2013/2016, EN 16147:2011
2014/68/EU: Pressure Equipment Directive*	ANNEX I of 2014/68/EU, Japanese High pressure gas safety law, Refrigeration safety regulation section 23

Please refer to <http://erp.mitsubishielectric.eu/erp> for more information of 2009/125/EC.

Information of 2014/68/EU Pressure Equipment

Pressure Component	Accumulator	Category II
	Pressure Switch	Category IV
Applied conformity assessment procedure:	Internal manufacturing checks with monitoring of the final assessment (module A2)	
The monitoring is performed by the Notified Body:	TÜV Rheinland Industrie Service GmbH Am Grauen Stein, D-51105 Cologne / Germany	

Issued date: 16 June, 2015

Revised date: 1 July, 2019



Katsuo YABUTA

Senior Manager, Quality Assurance Department
Shizuoka JAPAN